



APPARATUS MAINTENANCE

SCOPE

This guideline shall apply to all members of the Stoney Point Fire Department and shall be adhered to by all members.

PURPOSE

To insure that all apparatus are ready to respond and function in good working order when they are called upon.

DESCRIPTION

PLAN: Shift supervisors will insure all apparatus are inspected daily to include the following:

- Fuel is above three quarters of a tank
- Engine booster tanks are full
- Air pack bottles are showing at least 4000 psi.
- W/T's and mobile radios are accounted for
- Water coolers are filled with cold drinking water
- ISO sheets are completed

Policy Number

6A.007

Page 1 of 2

Each shift will be assigned a group of apparatus that they will be responsible for on a quarterly basis. **These apparatus should be inspected thoroughly using the D/O check list.**

Shift supervisors will also be responsible for proper care and inspection of generator and lighting systems, Fluid levels, Pumps, Air packs, Saws, Hose, Fans, and Tires. Any services that cannot be handled at the shift level shall be reported to the daytime supervisor, and recorded on a maintenance form.

To insure equipment is functional and clean, shift leaders will also schedule a quarterly inspection. Each apparatus will have a quarterly inspection performed which includes exterior wash and wax, compartment/cab detail, equipment functions check, ladder inspections, and fire hose washing and re-racking.



Quarterly Inspection Schedule

<u>Group 1</u>	<u>Group 2</u>	<u>Group 3</u>
1331	1332	1931
1361	1333	1311
1371	1376	1932
1362	1391	1941

Policy Number

6A.007

Page 2 of 2

Group	Jan-Mar 2010	Apr-Jun 2010	Jul-Sept 2010	Oct-Dec 2010
1	B	C	A	B
2	C	A	B	C
3	A	B	C	A

Group	Jan-Mar 2011	Apr-Jun 2011	Jul-Sept 2011	Oct-Dec 2011
1	A	B	C	A
2	B	C	A	B
3	C	A	B	C